



ELECTRICIDADE DE TIMOR LESTE, EMPRESA PÚBLICA  
EDTL, E.P.



COMISSÃO EXECUTIVA

**"SUPPLY AND DELIVERY OF LIGHT FUEL OIL TO CENTRAL ELECTRICITY OF EDTL IN  
COMORO SUB-STATION"**

**OCB/0062/EDTL-EP-2025**

Clarification No.1

6 August 2025

No.	Questions	Responses
1	What is the basis of MOPS for calculation?	The basis for MOPS is the date of purchase.
2	What is the size of EDTL central Comoro storage tank?	The capacity storage tank at Comoro Diesel Power Plant 4,411,355 litres, it means that can accommodate more than what is require for 1,851,206.00 litres.
3	What is the contract duration for this project?	Contract duration is 60 days, counted from the Employer issued Notice to Proceed.
4	How long the payment process it will take?	The Employer shall pay the contractor the amounts certified by project owner within <b>60 days</b> of payment certificate.
5	Should we also attach the proof of completion contracts?	Yes, this is mandatory Document for the evaluation purpose.
6	When the bid security can be release?	The Bid Security of unsuccessful Bidders shall be returned as promptly as possible upon the successful Bidder furnishing the Performance Security pursuant to ITB 20.4 and ITB 36.1.
7	What is the MOPS requirement for this particular tender?	The MOPS price required for this tender purpose published as on 4 August 2025, to be used only for evaluation purpose.  Please refer to ITB-BDS 14.1.
8	What is the final destiny of the fuel storage for this particular package?	The final destination is EDTL, EP. Tank at Central Comoro.
9	Did the one-time supplier deliver a total quantity of 1,851,206.40 Litres of Light Fuel Oil?	Yes, our storage tank at Comoro Diesel power plant has enough capacity to receive at once.
10	How many numbers of copies we need to submit for technical and price documents?	<b>The Bidder must submit:</b>  (a) Technical Bid: one (1) original and two (2) copies and one (1) electronic copy in USB; and (b) Price Bid: one (1) original + (2) copies and one (1) electronic copy in USB.
11	What is the minimum passing score of this particular tender?	The minimum passing score for this package is 75 points, moreover, the bidder bid that evaluated attend the 75 points, then invited for price bid opening.
12	What is the language to be used in this bid?	Yes, the language will be English if your proposal is in another official language, it will be considered.
13	Could you please clarify whether the bid security will be attached to the technical or price bid?	The Bid Security is submitted together in the original technical bid envelope.
14	as indicated in the invitation to bid and listed in the price schedule, the estimated cost and quantity of fuel for the package is unbalanced, please explain.	The estimated price and quantity of fuel listed in the invitation are not balanced due the estimated price per liter in the invitation is \$0.7779/liter, which causes an imbalance when multiplied by the quantity of fuel oil.

  
**Julio de Jesus Gonçalves**

Executive Commissioner of EDTL, E. P.

