



SUPPLY OF ELECTRICAL MATERIAL FOR EDTL, E.P.

Clarification No.2

12 April 2024

Nu.	Package Numbers	Queries	Response
1	OCB/0067/EDTL, E.P-2024	Cross Arm & Accessories What type and size of it"? (Item No.1-4) can we have the picture?	a. Type: 1. Single Cross arm type A1 balance support on single pole UNP 100-2000mm (100x50x4mm) for metal pole 2. double cross arm Type B3 balance double support on single pole UNP 100-2200mm (100x50x4mm) for metal pole. 3. Single Cross arm type A1 balance support on single pole UNP 100-2000mm (100x50x4mm) for Concrete pole. 4 double cross arm Type A3 balance double support on single pole UNP 100-2200mm (100x50x4mm) for Concrete pole. b. Picture: your request to come in EDTL warehouse to take the picture.
2	OCB/0067/EDTL, E.P-2024	On Nu. 17-18 about TAP CONNECTOR, what type/model of Tap Connector?	17. Joint connector Bimetal Al-Cu 50mm-95mm. 18. Joint connector Bimetal Al-Cu 70mm-120mm.
3	OCB/0067/EDTL, E.P-2024	MV &LV Accessories no. 31-32 not clear, is it 16x50mm or 16x130mm?	31. Bolt full drad 5/8" x 300 + ring (Galvanized). 32. Bolt & nut 5/8" x 150mm + ring (Galvanized).
4	OCB/0067/EDTL, E.P-2024	Street light LED 80-100Watt completed with armature structure is it Lumen or Chipset?	The required armature structure is Lumen.
5	OCB/0067/EDTL, E.P-2024	Contramust Assembly and Druckkschoor Assembly are with Poles or without poles?	Contramust Assembly and Druckkschoor Assembly are only accessories not include poles.
6	OCB/0067/EDTL, E.P-2024	Anti-climber protection is with Inch?	Yes, with Inch.
7	OCB/0069/EDTL, E.P-2024	Pada Section II. Bid data Sheet: ITB 2.1 tertulis: The employer has allocated funds from current year 2024 for this project the maximum Budget	YES. The allocated maximum cost for this particular package is USD 2,845,950.30 , for those bidders' price offer exceeded

Nu.	Package Numbers	Queries	Response
		<p>for this project is US\$ 2,845,950.30</p> <p>Sementara pada dokument IFB 4 lot Point No. 5: Proposal with a value does not reach 70% of the value of the procedure is considered abnormally low bid</p> <p>Yang ingin di tanyakan: Apakah The value of the procedure itu sama dengan the maximum budget?</p>	<p>the said budget will be DISQUALIFIED, in addition, for those prices offer lower 70 % than estimated cost it will consider abnormally low.</p>
8	OCB/0069/EDTL, E.P-2024	<p>Pada Section II. Bid Data Sheet: ITB 11.4 point "f" Apakah bisa di kirimkan form the Local Development Statement (Form LDS-1). karena di dalam dokumen tender 0069 kami tidak menemukan form LDS-1.?</p>	Not required.
9	OCB/0067/EDTL, E.P-2024, OCB/0068/EDTL, E.P-2024, OCB/0069/EDTL, E.P-2024, OCB/0070/EDTL, E.P-2024	<p>Pada section III bagian technical evaluation point 1: terdapat Signatory to the bid is authorized to commit the Bidder as Evidenced by a Power of Attorney submitted with the Bid. Apakah Perusahaan Tunggal perlu melampirkan Power of Attorney tersebut, jika yang menandatangani dokumen bid adalah direktur Perusahaan?</p>	If your bid was signed by the company director, power of attorney is not required.
10	OCB/0067/EDTL, E.P-2024, OCB/0068/EDTL, E.P-2024, OCB/0069/EDTL, E.P-2024, OCB/0070/EDTL, E.P-2024	<p>Pada Section IV-Bidding form: Bagian Price Bid Submission Sheet:</p> <ul style="list-style-type: none"> - Point (c) The total price of our Bid, excluding any discounts offered in item (d) below is USD.... (In wording) - Point (d) The discount offerded and the methodology for their application are: <p>Pertanyaannya: Kalau di point (c) tidak ada discount lagi, apakah pada point (d) nta kita isi N/A (not applicable) atau harus isi apa?</p>	If the bidder offer discount underprice bid, the nominal of the percentage (%) of discount must be stated.

Nu.	Package Numbers	Queries	Response
11	OCB/0067/EDTL, E.P-2024, OCB/0068/EDTL, E.P-2024, OCB/0069/EDTL, E.P-2024, OCB/0070/EDTL, E.P-2024	Pada Section IV-Bidding form: Bagian Supplier Qualification: untuk "Correspondent Information Sheet" apakah ada form tersebut dari EDTL-EP atau kami buat sendiri form tersebut?	The form of supplier qualification provided under section IV of bidding forms. In addition, the information of supplier qualification was listed under section III: Evaluation and Qualification Criteria (EQC).
12	OCB/0067/EDTL, E.P-2024, OCB/0068/EDTL, E.P-2024, OCB/0069/EDTL, E.P-2024, OCB/0070/EDTL, E.P-2024	Bersama ini kami ingin menanyakan: - Agen lokal di Timor-Leste yang di tunjuk, Dalam hal ini : untuk pembayaran Proyek 100% masuk ke rekening perusahaan kami ya?	It's depended on standing agreement between your company with your local agent. If the bidder participates as Joint Venture; the future partners must state in JV agreement.

Julio de Jesus Goncalves

Executive Commissioner of Corporate Services of EDTL, E. P.